



March 15, 2016

ADDENDUM NO. 1 TO ALL BIDDERS:

Invitation to Bid: ITB#16-07-20

Description: WEST END COMMERCIAL FAÇADE IMPROVEMENTS

Dated: February 29, 2016

For Delivery to: Purchasing Division, City of Roanoke, Virginia

Bid Due: March 22, 2016

The open date for the above referenced ITB#16-07-20 is hereby changed from March 22, 2016 to March 28, 2016.

Reference: Technical Specifications, as it pertains to 631 Campbell Avenue, Change:

Section 08411 - 32.4, Entrance Hardware:

Change the exterior lockset at the primary building entrances (the new lower level entrance on the Western Facade, and entrance that is 2nd from the right on the South Facade) to provide electric strikes that are compatible with the electronic call box by PACH AeGIS Entry System to be provided by Owner.

At the secondary entrances (central double door and far right single door on the South Facade), provide rough-ins for both a strike and a deadbolt. The Owner will provide the hardware.

Note: A signed acknowledgment of this addendum should be received at the location indicated on the ITB either prior to the due date and hour or attached to your response. Signature on this addendum does not substitute for your signature on the original bid document. The original bid document must be signed.

Very truly yours,

Monica Cole 
Senior Buyer
Phone: 540-853-2871

Name of Firm

Signature/Title

Date