

ITB#16-03-04
Brick Sidewalk Repair
Pre-bid Notes
November 16, 2015, 10:30a.m.

As noted in the ITB:

On the sidewalks, you do not have to use the high early concrete when the temperature is 70 degrees F or higher.

Inlet protections must be up to date. Be mindful of the environmental concerns and appropriate covers.

Work zones must be set up by VDOT standards.

Should there be any concern about trees/roots, the Successful Bidder may coordinate with the Transportation Division inspector, ***after award of bid***. The City will manage root concerns. The City will meet with the Successful Bidder at each location as appropriate, prior to commencement of the work.

The Successful Bidder must be ICPI Certified.

Questions-

Q. How will brick be patterned?

A. Brick shall be patterned to match the original brick pattern as closely as possible. See Addendum No. 1.

Q. Where will star bricks be applied?

A. See Addendum No. 1.

Q. Will the City dictate which color brick will be applied at each location?

A. Yes.