



cc

Subject RFP for DDC Controls

Sorry, I have two more question.

At the walk through it was stated:

1. The heat exchanger and associated pumps were to be controlled.

Please provide sketch and points. **please see attached drawing.**

2. The perimeter fan coils had a controller in a 5th floor office of the North Building

What points do you want included. **Municipal north has 5 floors and each floor should have a start stop and status of all fan coils with scheduling and overriding capabilities**